

## MD SERIES - SPECIFICATION DATA SHEET 3.4



[www.kirkkey.com](http://www.kirkkey.com)

**Luft Brasil Ind. Com. Ltda**

R. Dom Andrés Lamas, 56  
Tataupé São Paulo - SP  
(11) 3795-0000

[www.luftbrasil.com.br](http://www.luftbrasil.com.br)



**Interlock System Keys**



KIRK® MD Series Key (part # H7006)

KIRK® MD Series keys are made from 316 stainless steel. The shaft driven design contains precision drivers configured to specific combinations. Each key has a gasket to prevent entry of dirt or moisture into the interlock. MD Series keys can only be furnished to you by Kirk Key Interlock Company.

### OPTIONS

Stamp Key Interchange – specify an alphanumeric code to be stamped on the cylinder face and the key (e.g. A1, A2, B1, etc). The key interchange can be up to five characters long.

### Duplicate Keys

Each MD Series interlock system is supplied with the precise number of keys specified. If extra (installation) keys are specified, the extra keys must be removed from the system after installation and destroyed or secured/controlled by a responsible person.

If additional keys are required due to loss or damage, please:

1. Print the Duplicate Key Release Form from our web site.
2. Complete the form and sign your name.
3. Fax the form and your purchase order to Kirk Key Interlock Company at (330) 833-1528 for immediate delivery.

### Record Keeping

With our extensive record keeping dating back to 1945, you can rely on Kirk Key Interlock Company to coordinate and number your keys in coordination with existing equipment currently in service.

**Caution:** the existence of duplicate keys in a KIRK® interlock system may compromise the safety of the system. To ensure correct operation of the KIRK® interlock system, it is necessary to remove all loosely or removably held keys before operating the equipment on which the interlocks are mounted. Keys removed from an interlock system should be destroyed or retained by authorized personnel.

# MD SERIES - SPECIFICATION DATA SHEET 3.4



[www.kirkkey.com](http://www.kirkkey.com)


Luft Brasil Ind. Com. Ltda

R. Dom Andrés Lamas, 56  
Tataupé São Paulo - SP  
(11) 3795-0000

[www.luftbrasil.com.br](http://www.luftbrasil.com.br)



## Interlock System Keys



### Notes:

- 1) Key interchange (optional) - the key interchange is stamped on the back side (or finger side) of the key.
- 2) Lock number - always stamped on key and lock. This number is assigned by Kirk Key Interlock Company unless specified when ordering. The lock number is stamped on the front side (or thumb side) of the key.
- 3) Gasket - to prevent debris and moisture from entering interlock cylinder.